

Test Report

Resistance to wind load

Test report No.: 2023-0011-002_en

Owner **VIOMAL S.A.**
Vatonta N.Artakis
34600 N.Artaki
Greece

Product **Vertical zip blind**

System Designation **Shading System**

Manufacturer **VIOMAL S.A.**

Material Screen **Fiberglass**

Overall dimensions
(WxH) **3,005 mm x 2,990 mm**

Special features **-/-**

Results

Resistance to wind loads according to EN 13561-2015-05 + AC:2016-03-
Classification according to Commission delegated regulation (EU)
2019/1188: 2019-03

W_{2,925} x H_{2,890} Class: 5

PLANECO Mon. EPE
21 March 2024



Dr. Georgios Moustakidis
General Manager



PLANECO

DEVELOPMENT CONSULTANTS

Basis

EN 13561:2015-05+AC:2016-03
External blinds and awnings -
Performance requirements
including safety

*)and corresponding national versions e.g. EAOTEN

EN 1932 : 2013-06
External blinds and shutters –
Resistance to wind loads –
Method of testing an
performance criteria

Method N°3:
use of a pneumatic device

Representation



Test Rig

LWW Test Rig – CFT P.C.
Calibrated by ift Rosenheim

Instruction for use

The results obtained can be used
by the manufacturer for
preparing the Declaration of
Performance in accordance with
the Construction Products
Regulation 305/2011/EU. The
provisions of the applicable
product standard have to be
observed.

Validity

There is no time limit.

When using this document the
up-to-dateness of above basis
and the conformity of the
product have to be observed.

The report contains a total of
12 pages